



Queensland Government Gazette

EXTRAORDINARY

PUBLISHED BY AUTHORITY

ISSN 0155-9370

Vol. 366]

FRIDAY 9 MAY 2014

[No. 10

Department of Justice and Attorney-General
9 May 2014

Department of Justice and Attorney-General
9 May 2014

**PROHIBITION OF SALE AND USE OF ELECTRICAL EQUIPMENT
UNDER THE *ELECTRICAL SAFETY ACT 2002***

I, BRIAN RICHARDSON, Director Equipment Safety and Licensing, Department of Justice and Attorney-General, being the delegate of the regulator, acting under the *Electrical Safety Act 2002*, on reasonable belief that the below type does not comply with the safety criteria in AS/NZS 3820 (Essential safety requirements for electrical equipment), prohibit the sale or installation by any person of:

Avanco branded rotary type DC isolators model numbers:

AV/DC4P25AUB, AV/DC2P625AU, AV/DC2P25AU,
AV/DC2/2P25AU, AV/DC2/2P125AU, AV/DC4P25AU,
AV/DC4P25AUS, and AV/DC4P25AUT.

The prohibition of sale or installation is effective from the date of publication of this notice in the Queensland Gazette.

BRIAN RICHARDSON
Director Equipment Safety and Licensing
Department of Justice and Attorney-General

**MINISTERIAL RECALL ORDER ELECTRICAL EQUIPMENT UNDER
THE *ELECTRICAL SAFETY ACT 2002***

The, Hon. Jarrod Bleijie, Attorney-General and Minister for Justice, in accordance with the *Electrical Safety Act 2002*, Part 2, Division 2B, has made a Ministerial recall order on Advancetech Pty Ltd as the importer of electrical equipment listed below. This order was made on 8 May 2014.

The electrical equipment is:

AVANCO brand DC solar isolators that may be used for photovoltaic (PV) systems with the model numbers:

AV/DC4P25A, AV/DC2P25A AV/DC4P25AUB,
AV/DC2P625AU, AV/DC2P25AU, AV/DC2/2P25AU,
AV/DC2/2P125AU, AV/DC4P25AU, AV/DC4P25AUS,
and AV/DC4P25AUT.

The product features an internal fault in the isolator that leads to overheating and fire.

This page has been left blank intentionally