



# Queensland Government Gazette

**EXTRAORDINARY**

**PUBLISHED BY AUTHORITY**

ISSN 0155-9370

**Vol. 366]**

**FRIDAY 30 MAY 2014**

**[No. 30**

**NOTICE OF A MINISTERIAL DESIGNATION OF LAND  
FOR COMMUNITY INFRASTRUCTURE  
MADE UNDER THE *SUSTAINABLE PLANNING ACT 2009***

I, MARK McARDLE MP, Minister for Energy and Water Supply, give notice:

**A Ministerial designation has been made**

A designation of land for community infrastructure pursuant to section 200 of the *Sustainable Planning Act 2009* has been made. The designation is in respect of land on which Queensland Electricity Transmission Corporation Limited, trading as Powerlink Queensland, proposes to build community infrastructure.

**Description of the land to which the designation applies**

The land designated consists of a corridor of easements and areas of land as described in the table below:

Easement/ Area ID	Easement/Area Plan No.	Property Lot No.	Property Survey Plan No.	Local Government
I	EU-FV-0003	9	AB244	Banana Shire Council
I	EU-FV-0003	9	AB244	Maranoa Regional Council
G	SP261991	2	AB247	Banana Shire Council
H	SP261991	2	AB247	Banana Shire Council
CIDA	EU-FV-0002	INJUNE ROAD		Banana Shire Council
E	SP261990	8	SP261936	Banana Shire Council
F	SP261990	8	SP261936	Banana Shire Council
D	SP261989	6	CP908635	Maranoa Regional Council
F	SP261988	5	SP261934	Maranoa Regional Council
G	SP261988	5	SP261934	Maranoa Regional Council
H	SP261988	5	SP261934	Maranoa Regional Council
CIDA	EU-FV-0001	FAIRVIEW ROAD		Maranoa Regional Council
CIDA	EU-FV-0001	UNNAMED ROAD		Maranoa Regional Council
CIDA	EU-FV-0001	FAIRVIEW ROAD		Maranoa Regional Council

**Type of community infrastructure for which the land has been designated**

The type of community infrastructure for which the land has been designated is operating works under the *Electricity Act 1994*. Specifically, these operating works are the Eurombah to Fairview South to Fairview Transmission Line Project, consisting of:

- a new 24.4 kilometre (km) 275 kilovolt (kV) double circuit transmission line from Powerlink's proposed Eurombah Substation, approximately 64km south-east of Injune, to the proposed Powerlink Fairview South substation, approximately east of Injune;
- a new 2.7km 132kV connection from the proposed Fairview South Substation to the Santos GLNG F04 switchyard;
- a new 24.4km 132kV double circuit transmission line from the proposed Fairview South Substation to the proposed Powerlink Fairview Substation, approximately 45km north-east of Injune;
- a new 2.6km 132kV connection from the proposed Fairview Substation to the Santos GLNG F05 switchyard.

MARK McARDLE MP  
Minister for Energy and  
Water Supply  
Dated: 29 May 2014

